

**From:** [webmaster@cpuc.ca.gov](mailto:webmaster@cpuc.ca.gov) <[webmaster@cpuc.ca.gov](mailto:webmaster@cpuc.ca.gov)>

**Sent:** Monday, October 28, 2019 2:03:07 AM

**To:** [usrb@cpuc.ca.gov](mailto:usrb@cpuc.ca.gov) <[usrb@cpuc.ca.gov](mailto:usrb@cpuc.ca.gov)>

**Cc:** Allen, Meredith <[MEAe@pge.com](mailto:MEAe@pge.com)>

**Subject:** Electric Safety Incident Reported- PG&E Incident No: 191028-9398

**\*\*\*\*\*CAUTION: This email was sent from an EXTERNAL source. Think before clicking links or opening attachments.\*\*\*\*\***

**The Following information regarding this incident has been reported:**

**Reporting Date:** 10/28/2019 1:43:47 AM

**Incident Date:** 10/27/2019 @ 2:45 p.m.

**Reported By:** Meredith Allen, Sr. Director

**Utility Name:** PG&E

**Phone Number:** (415)828-5765

**Email Address:** [MEAe@pge.com](mailto:MEAe@pge.com)

**Incident Location:** Marylinn and Barker St Milpitas, Santa Clara

**Reasons For Reporting:**

- Fatalities? No (Utility: , Others: )
- Names of Fatalities:
- Injuries? (Utility: , Others: )
- Names of Injured:
- Damage? Yes (Utility: , Others: )
- Interruption? (Total Customers: , Total Hours: )
- Operator Judgement? No
- Media Coverage? No

**Cause of Incident:** Unknown (Other Cause: )

**Agencies on Scene:** Fire,

**Facilities Affected:**

- Utilities Facilities: Dixon Landing 2102
- Voltage (KV): 12
- Customer's Facilities:

**DigIn Information:**

- Excavator Name:
- Contact:
- Phone: (\_\_\_\_)\_\_\_\_ - \_\_\_\_\_

**Incident Recovery:**

- On Scene Date & Time: @ 00:00 a.m.
- Service Restored: @ 00:00 a.m.

**Summary:** At approximately 2130 hours on October 27, 2019, PG&E Troublemens responded to trouble near Marylinn Drive and Barker Street in Milpitas, CA near the location of a fire. At the location, the Troublemens observed wire down. They observed two houses, two cars, and a shed damaged by the fire. An on site Milpitas Fire Department Investigator informed the troubleman that he was looking at the downed wire as a potential ignition source and collected a portion of the conductor into evidence. The incident location is not in Tier 3, Tier 2, or Tier 1 High Hazard Zone High Fire Threat District. PG&E is reporting this incident under the Property Damage Criterion. This information is preliminary.